



### Lifting Accessories of Visual and Thorough Examination

This Certificate complies with the requirements of the Lifting Equipment Operations and Lifting Equipment Regulations

Client:	EMC Company	Certificate no:	QC-B-03-25-0077/07/01
Location:	8 TH STATION	Job Order No.:	QC-B-03-25-0077
Date of Examination:	08-Mar-2025	Next Inspection Due:	07-Sep-2025
Last Inspection 10-Nov-2024		Last Proof Load Test Date By Manufacture	

IDENTIFICATION NO	DESCRIPTION	QTY	SWL
<b>T18040423</b>	<b>CHAIN HOIST</b>  <b>Manufacture: TOYO</b>  <b>Model: TCB-020</b> <b>Lift: 3m</b> <b>Grade: 80</b> <b>F.O.S: 4:1</b>	01	2 Ton



Reference Standard:	BS EN 13157: 2004 + A1: 2009
---------------------	------------------------------

Is this the first examination after Installation or assembly at a new site or location?	YES	NO	v	Was the examination carried out: Within an interval of 6 months? With an interval of 12 months? By an examination scheme? After the occurrence of exceptional circumstances?	YES	v	NO	
					YES		NO	v
If the answer to the above question is YES has the equipment been installed correctly?	YES	NO			YES	v	NO	
					YES		NO	v

Identification of any part found to have a defect which is or could not become a danger to persons and a description of the defect: (If none State NONE) **NONE**



Is the above a defect which is of immediate danger to persons: YES  NO

Is the above a defect which is not yet but could become a danger to persons (If YES state the date by when) **N/A**

Particulars of any repair, renewal, or alteration required to remedy the defect identified above:

Particulars of any tests carried out as part of the examination: (If none state NONE)  
 The subject Items were inspected Visually and dimensionally where no signs of defects were observed at the time of inspection and found satisfactory

**IS THIS EQUIPMENT SAFE TO OPERATE?** YES  NO

LEEA & ASNT Level II Inspector Name:	Signature	Authenticating This Report:	Signature
<b>Khaled Mahmoud</b>		<b>Mohammed Abdullah</b>	

**THIS IS TO CERTIFY THAT:** a competent person did attend the owner mentioner's work location on the date shown above and the Equipment described in this report was tested & inspected as per the requirements of Lifting Operations Lifting Equipment Regulation "LOLER". The result was found Satisfactory at the time of Inspection and considered Safe for Lifting.






### Lifting Accessories of Visual and Thorough Examination



This Certificate complies with the requirements of the Lifting Equipment Operations and Lifting Equipment Regulations

Client:	EMC Company	Certificate no:	QC-B-03-25-0077/07/02
Location:	8 TH STATION	Job Order No.:	QC-B-03-25-0077
Date of Examination:	08-Mar-2025	Next Inspection Due:	07-Sep-2025
Last Inspection		Last Proof Load Test Date	
10-Nov-2024		By Manufacture	

IDENTIFICATION NO	DESCRIPTION	QTY	SWL
<b>T22110416</b> <b>T21031326</b> <b>T22041113</b>	<p align="center"><b>CHAIN HOIST</b></p> <p><b>Manufacture: TOYO</b></p> <p><b>Model: TCB-030</b></p> <p><b>Lift: 3m</b></p> <p><b>Grade: 80</b></p> <p><b>F.O.S: 4:1</b></p> 	03	3 Ton

Reference Standard: BS EN 13157: 2004 + A1: 2009

Is this the first examination after Installation or assembly at a new site or location?	YES		NO	v	Was the examination carried out: Within an interval of 6 months? With an interval of 12 months? By an examination scheme? After the occurrence of exceptional circumstances?	YES	v	NO			
						YES		NO	v		
If the answer to the above question is YES has the equipment been installed correctly?	YES		NO			YES	v	NO			
						YES		NO	v		
Identification of any part found to have a defect which is or could not become a danger to persons and a description of the defect: (If none State NONE) <b>NONE</b>											
Is the above a defect which is of immediate danger to persons:								YES		NO	v
Is the above a defect which is not yet but could become a danger to persons (If YES state the date by when)								N/A			
Particulars of any repair, renewal, or alteration required to remedy the defect identified above:											
Particulars of any tests carried out as part of the examination: (If none state NONE) The subject Items were inspected Visually and dimensionally where no signs of defects were observed at the time of inspection and found satisfactory											
<b>IS THIS EQUIPMENT SAFE TO OPERATE?</b>								YES	v	NO	

LEEA & ASNT Level II Inspector Name:	Signature	Authenticating This Report:	Signature
<b>Khaled Mahmoud</b>		<b>Mohammed Abdullah</b>	


**THIS IS TO CERTIFY THAT:** a competent person did attend the owner mentioner's work location on the date shown above and the Equipment described in this report was tested & inspected as per the requirements of Lifting Operations Lifting Equipment Regulation "LOLER". The result was found Satisfactory at the time of Inspection and considered Safe for Lifting.



### Lifting Accessories of Visual and Thorough Examination



This Certificate complies with the requirements of the Lifting Equipment Operations and Lifting Equipment Regulations

Client:	EMC Company	Certificate no:	QC-B-03-25-0077/07/03
Location:	8 TH STATION	Job Order No.:	QC-B-03-25-0077
Date of Examination:	08-Mar-2025	Next Inspection Due:	07-Sep-2025
Last Inspection		Last Proof Load Test Date	
10-Nov-2024		By Manufacture	

IDENTIFICATION NO	DESCRIPTION	QTY	SWL
T21051752 T21051770	<b>LEVER HOIST</b>  <b>Manufacture: TOYO</b>  <b>Model: TLB-300</b> <b>Lift: 1.5 m</b> <b>Grade: 80</b> <b>F.O.S: 4:1</b>	02	3 Ton
			

Reference Standard: BS EN 13157: 2004 + A1: 2009

Is this the first examination after Installation or assembly at a new site or location?	YES		NO	v	Was the examination carried out: Within an interval of 6 months? With an interval of 12 months? By an examination scheme? After the occurrence of exceptional circumstances?	YES	v	NO	
						YES		NO	v
If the answer to the above question is YES has the equipment been installed correctly?	YES		NO			YES	v	NO	
						YES		NO	v
Identification of any part found to have a defect which is or could not become a danger to persons and a description of the defect: (If none State NONE) <b>NONE</b>									
Is the above a defect which is of immediate danger to persons:						YES		NO	v
Is the above a defect which is not yet but could become a danger to persons (If YES state the date by when)						N/A			
Particulars of any repair, renewal, or alteration required to remedy the defect identified above:									
Particulars of any tests carried out as part of the examination: (If none state NONE) The subject Items were inspected Visually and dimensionally where no signs of defects were observed at the time of inspection and found satisfactory									
<b>IS THIS EQUIPMENT SAFE TO OPERATE?</b>						YES	v	NO	

LEEA & ASNT Level II Inspector Name:	Signature	Authenticating This Report:	Signature
<b>Khaled Mahmoud</b>		<b>Mohammed Abdullah</b>	


**THIS IS TO CERTIFY THAT:** a competent person did attend the owner mentioner's work location on the date shown above and the Equipment described in this report was tested & inspected as per the requirements of Lifting Operations Lifting Equipment Regulation "LOLER". The result was found Satisfactory at the time of Inspection and considered Safe for Lifting.



### Lifting Accessories of Visual and Thorough Examination



This Certificate complies with the requirements of the Lifting Equipment Operations and Lifting Equipment Regulations

Client:	EMC Company	Certificate no:	QC-B-03-25-0077/07/04
Location:	8 TH STATION	Job Order No.:	QC-B-03-25-0077
Date of Examination:	08-Mar-2025	Next Inspection Due:	07-Sep-2025
Last Inspection		Last Proof Load Test Date	
10-Nov-2024		By Manufacture	

IDENTIFICATION NO	DESCRIPTION	QTY	SWL
T19070901 T19080312 T1908028	<p style="text-align: center;"><b>LEVER HOIST</b></p> <p><b>Manufacture: TOYO</b></p> <p><b>Model: TLB-150</b></p> <p><b>Lift: 1.5 m</b></p> <p><b>Grade: 80</b></p> <p><b>F.O.S: 4:1</b></p> 	03	1.5 Ton

Reference Standard: BS EN 13157: 2004 + A1: 2009

Is this the first examination after Installation or assembly at a new site or location?	YES		NO	v	Was the examination carried out: Within an interval of 6 months? With an interval of 12 months? By an examination scheme? After the occurrence of exceptional circumstances?	YES	v	NO			
						YES		NO	v		
If the answer to the above question is YES has the equipment been installed correctly?	YES		NO			YES	v	NO			
						YES		NO	v		
Identification of any part found to have a defect which is or could not become a danger to persons and a description of the defect: (If none State NONE) <b>NONE</b>											
Is the above a defect which is of immediate danger to persons:								YES		NO	v
Is the above a defect which is not yet but could become a danger to persons (If YES state the date by when)								N/A			
Particulars of any repair, renewal, or alteration required to remedy the defect identified above:											
Particulars of any tests carried out as part of the examination: (If none state NONE) The subject Items were inspected Visually and dimensionally where no signs of defects were observed at the time of inspection and found satisfactory											
<b>IS THIS EQUIPMENT SAFE TO OPERATE?</b>								YES	v	NO	

LEEA & ASNT Level II Inspector Name:	Signature	Authenticating This Report:	Signature
<b>Khaled Mahmoud</b>		<b>Mohammed Abdullah</b>	

**THIS IS TO CERTIFY THAT:** a competent person did attend the owner mentioner's work location on the date shown above and the Equipment described in this report was tested & inspected as per the requirements of Lifting Operations Lifting Equipment Regulation "LOLER". The result was found Satisfactory at the time of Inspection and considered Safe for Lifting.