

Certificate of SCBA Hydrostatic Test

Equipment Under Testing Details.

Customer Tareek Al-Salem Company	Certificate No. QC-CAL-25233-11
Description SCBA Cylinder	Issue Date June 14, 2025
MFG N/A	Due Date June 13, 2030
Job Number QC-CAL-25233	

Standard Instrument Details.

Serial No. 468802	Accuracy ± 0.25 %FS
Description Digital Pressure Gauge	Cal Due Date November 4, 2025
MFG AMETEK	Model XP2i

Test Results:

The equipment under testing was/were tested up to maximum test pressure according to used standard testing method. The following give the corresponding reference mean readings:

#	S/N	Description	MODEL	Working Pressure (bar)	Test Pressure (bar)	Holding Time (Min)
1	XPH025UT	SCBA CYLINDER	M18	200	300	15

Final Result:

We hereby certify that the above equipment had been tested to the test pressure indicated above in a constant temperature and found satisfactory where no visible leak or pressure drop observed during the pressure tests.

- The equipment is/are in specification.
- This test was carried out in compliance with ASME code Section V Article 10 & 27.
- The standard/standards used in this test is/are traced to SI unit of pressure through traceability to primary standard maintained in the National Institute of Standards (NIS).
- This certificate may not be reproduced other than in full by photographic process.
- This certificate refers only to the particular item/items submitted for testing.
- This certificate is valid only with signature and stamp.

Tested by: Asjad Rafiq

Signature:

