

## Test Certificate-Fire Extinguisher

<b>Job Number :</b>	<b>QC/JN/24/00177</b>	<b>EXAMINATION DATE</b>	<b>15/06/2024</b>
<b>Report Number :</b>	<b>QC240615-01</b>	<b>EXP.DATE</b>	<b>14/06/2025</b>
<b>Customer Name:</b>	<b>Halliburton Worldwide Iraq.</b>	<b>Location :</b>	<b>Basra, South Iraq</b>
<b>Department :</b>	<b>TSS</b>		
<b>Testing And Inspection Method:</b>	Based On NFPA (National Fire Protection Association); NFPA 10: Standard For Portable Fire Extinguisher.		

THIS IS TO CERTIFY THAT 'WE AT Quality Control (ALTAKAMUL)  
Have Inspected; Serviced& Refilled Below Stated Items:

Sr.	Extinguisher Type	Serial Number	DESCRIPTION	Weight	Refilling	Maintenance & inspected	Remarks.
01	Powder	000585	FIRE EXTINGUISHER	12 Kg	✓	✓	Pass
02	Powder	61697	FIRE EXTINGUISHER	08 Kg	✓	✓	Pass

THE ABOVE FIRE EXTINGUISHERS ARE FREE FROM PATENT DEFECTS AND SUITABLE FOR FURTHER USE (IN THE TIME OF INSPECTION)

### ENVIRONMENTAL CONDITIONS DURING TESTING:

<b>HUMIDITY 40.3 % RH</b>	<b>TEMPERATURES MEAN: 25.9°C</b>
---------------------------	----------------------------------

**Tested By:** Asjad Rafiq

**MASTER LOG CERTIFICATE (NEBOSH)**



**Signature:**



00136995/38678

