

Test Certificate-Fire Extinguisher

QC Job Number :	QC/JN/24/00285	EXAMINATION DATE	20/07/2024
QC Report Number :	QC240720-01	EXP.DATE	19/07/2025
Customer Name: Department :	Halliburton Worldwide Iraq. HPS	Location :	Basra, South Iraq
Testing And Inspection Method:	Based On NFPA (National Fire Protection Association); NFPA 10: Standard For Portable Fire Extinguisher.		

THIS IS TO CERTIFY THAT 'WE AT Quality Control (ALTAKAMUL) Have Inspected; Serviced& Refilled Below Stated Items:

Sr.	Extinguisher Type	Serial Number	DESCRIPTION	Weight	Refilling	Maintenance & inspecte	Remarks
01	Powder	316816	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
02	Powder	316730	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
03	Powder	315875	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
04	Powder	315822	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
05	Powder	315821	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
06	Powder	315802	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
07	Powder	317059	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
08	Powder	315473	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
09	Powder	315836	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
10	Powder	315818	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass

THE ABOVE FIRE EXTINGUISHERS ARE FREE FROM PATENT DEFECTS AND SUITABLE FOR FURTHER USE (IN THE TIME OF INSPECTION)

ENVIRONMENTAL CONDITIONS DURING TESTING:

HUMIDITY 15 % RH	TEMPERATURES MEAN: 25.9°C
------------------	---------------------------

Tested By: Asjad Rafiq

Signature:



MASTER LOG CERTIFICATE (NEBOSH)

00136995/38678

