

Test Certificate-Fire Extinguisher

QC Job Number :	QC/JN/24/00275	EXAMINATION DATE	10-07-2024
QC Report Number :	QC240710	EXP.DATE	09-01-2025
Customer Name: Department :	Halliburton Worldwide IRAQ (HPS)	Location :	Basra, South Iraq
Testing And Inspection Method:	Based On NFPA (National Fire Protection Association); NFPA 10: Standard For Portable Fire Extinguisher.		

THIS IS TO CERTIFY THAT 'WE AT Quality Control (ALTAKAMUL) Have Inspected; Serviced& Refilled Below Stated Items:

Sr.	Extinguisher Type	Serial Number	DESCRIPTION	Weight	Refilling	Maintenance & inspected	Remarks.
01	Powder	00837	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
02	Powder	01120	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
03	Powder	09823	FIRE EXTINGUISHER	12 Kg	✓	✓	Pass
04	Powder	09408	FIRE EXTINGUISHER	12 Kg	✓	✓	Pass
05	Foam	0110	FIRE EXTINGUISHER	09 L	✓	✓	Pass
06	Powder	008640	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
07	Powder	69150	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
08	Powder	68486	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass
09	Powder	68505	FIRE EXTINGUISHER	06 Kg	✓	✓	Pass

THE ABOVE FIRE EXTINGUISHERS ARE FREE FROM PATENT DEFECTS AND SUITABLE FOR FURTHER USE (IN THE TIME OF INSPECTION)

ENVIRONMENTAL CONDITIONS DURING TESTING:

HUMIDITY 40.3 % RH	TEMPERATURES MEAN: 25.9°C
--------------------	---------------------------

Tested By: Hussein Alaa

MASTER LOG CERTIFICATE (NEBOSH)

Signature:



00136995/38678

