

## Test Certificate-Fire Extinguisher

<b>QC Job Number :</b>	QC/JN/24/00300	<b>EXAMINATION DATE</b>	26/7/2024
<b>QC Report Number :</b>	QC240726-06	<b>EXP.DATE</b>	25/1/2025
<b>Adress: Rig:</b>	DPAB Co.Ltd Iraq Branch Block-9 (DQ043)	<b>Location :</b>	Basra, South Iraq
<b>Testing And Inspection Method:</b>	Based On NFPA (National Fire Protection Association); NFPA 10: Standard For Portable Fire Extinguisher.		

THIS IS TO CERTIFY THAT 'WE AT Quality Control (ALTAKAMUL) Have Inspected; Serviced& Refilled Below Stated Items:

Sr.	Extinguisher Type	Serial Number	DESCRIPTION	Weight	Refilling	Maintenance & inspected	Remarks.
01	Powder	023397	FIRE EXTINGUISHER	8 kg	√	√	Pass
02	Powder	008755	FIRE EXTINGUISHER	8 kg	√	√	Pass
03	Powder	004026	FIRE EXTINGUISHER	8 kg	√	√	Pass
04	Powder	008667	FIRE EXTINGUISHER	8 kg	√	√	Pass
05	Powder	008806	FIRE EXTINGUISHER	8 kg	√	√	Pass
06	Powder	064086	FIRE EXTINGUISHER	8 kg	√	√	Pass
07	Powder	008275	FIRE EXTINGUISHER	8 kg	√	√	Pass
08	Powder	150359	FIRE EXTINGUISHER	9 kg	√	√	Pass
09	Powder	150421	FIRE EXTINGUISHER	9 kg	√	√	Pass
10	Powder	99608	FIRE EXTINGUISHER	12 kg	√	√	Pass
11	Powder	068627	FIRE EXTINGUISHER	12 kg	√	√	Pass
12	Powder	140285	FIRE EXTINGUISHER	12 kg	√	√	Pass

THE ABOVE FIRE EXTINGUISHERS ARE FREE FROM PATENT DEFECTS AND SUITABLE FOR FURTHER USE (IN THE TIME OF INSPECTION)

**ENVIRONMENTAL CONDITIONS DURING TESTING:**

HUMIDITY 41.0 % RH ±3%	TEMPERATURES MEAN: 36.0°C ±5°C
------------------------	--------------------------------

**Tested By:**

Hussein Alaa

**Signature:**



**MASTER LOG CERTIFICATE (NEBOSH)**

00136995/38678

