

## Test Certificate-Fire Extinguisher

QC Job Number	: QC/JN/24/00303	EXAMINATION DATE	31/07/2024
QC Report Number	: QC240731-01	EXP.DATE	30/07/2025
Customer Name: Department :	Nibras Al-Janoob Co.	Location :	Basra, South Iraq
Testing And Inspection Method:	Based On NFPA (National Fire Protection Association); NFPA 10: Standard For Portable Fire Extinguisher.		

THIS IS TO CERTIFY THAT 'WE AT Quality Control (ALTAKAMUL) Have Inspected; Serviced& Refilled Below Stated Items:

Sr.	Extinguisher Type	Serial Number	DESCRIPTION	Weight	Refilling	Maintenance & inspecte	Remarks
01	CO2	364	FIRE EXTINGUISHER	25 Kg	√	√	Pass
02	CO2	222	FIRE EXTINGUISHER	25 Kg	√	√	Pass
03	CO2	230	FIRE EXTINGUISHER	25 Kg	√	√	Pass
04	CO2	467	FIRE EXTINGUISHER	25 Kg	√	√	Pass
05	Powder	251	FIRE EXTINGUISHER	25 Kg	√	√	Pass
06	Powder	252	FIRE EXTINGUISHER	25 Kg	√	√	Pass
07	Powder	253	FIRE EXTINGUISHER	25 Kg	√	√	Pass

THE ABOVE FIRE EXTINGUISHERS ARE FREE FROM PATENT DEFECTS AND SUITABLE FOR FURTHER USE (IN THE TIME OF INSPECTION)

### ENVIRONMENTAL CONDITIONS DURING TESTING:

HUMIDITY 15 % RH	TEMPERATURES MEAN: 25.9°C
------------------	---------------------------

Tested By: Asjad Rafiq

MASTER LOG CERTIFICATE (NEBOSH)

Signature:



00136995/38678

