


Certificate of Calibration

Al Takamul Yard, North Rumailah South Iraq

• Phone : +964 7810009138 • www.qualitycontrol-iraq.com • E-mail: op@qualitycontrol-iraq.com

Date of Issue: November 17, 2024

REQUEST NUMBER : By Contract JOB NUMBER : QC-YB-240055 CERTIFICATE NUMBER : QC-YB-240055-010	APPROVED BY:  QA CHARGE
--	---

CUSTOMER DETAILS

Name : **slb Basra**
 Address : North Rumaila Base south Iraq
 Department : Testing

EQUIPMENT IDENTIFICATION AND SPECIFICATIONS

Description : **Pressure Relief Valve**
 Manufacturer : LEENGATE
 Model : NA
 Serial Number : **37557**
 Location : ESD-CD-874
 Set/Pressure : 100 psi
 Tolerance : ±3 %
 Calibrated By : Hussein Alaa
 Calibration Date : November 17, 2024
Calibration Due : **November 16, 2025**
 Last Calibration : NA



ENVIRONMENTAL CONDITIONS DURING TEST

Ambient Temperature : 25.0 ± 1°C Humidity : 44.0 ± 5 % RH Atm. Pressure : 1011.0 ± 10 hPa

CALIBRATION METHOD

Standard Method API 527 was used to test the unit under test. Test pressure was applied on inlet of unit under test and test was repeated 3 times. Identical repetitions were carried out as recommended in used standard.

REFERENCE EQUIPMENT USED

DESCRIPTION	SERIAL NO.	MAKE / MODEL	CALIBRATION DATE	CALIBRATION DUE DATE
Digital Pressure Gauge	1505119397	Sino Instruments / HS108	5 Nov, 2024	4 Nov, 2025

CALIBRATION TEST RESULTS

Measured Values on Unit Under Calibration (M)	Ref. Standard Values (A)	Deviation (D=M-A)	Tolerance Limit
psi	psi	psi	± psi
100	101.2	-1.2	3.00

Results :

The above Value Indicates That the Instrument complies with the Specified Maximum Permissible error tolerance.

At The Time of Calibration. and ready for use.

DEVIATION FROM STANDARD METHOD : None

REMARK (S) :

- The results relate to measurements taken at nominal value only.
- Adjustments were made prior to calibration.
- Accessories were fitted.

~ END OF DOCUMENT ~