







**AI TAKAMUL COMPANY FOR ENGINEERING TESTS  
AND PROFESSIONAL SAFETY LIMITED**  
Basra, North Rumaila, Quality Control Yard - Iraq



CERTIFICATION OF VISUAL, THOROUGH EXAMINATION & MAGNETIC PARTICLE INSPECTION												
<b>Client:</b>		MASAR ALTAMAYZ COMPANY			<b>Report No:</b>		QC-YB-240145-MTC-001					
<b>Location:</b>		KLO1			<b>Job Number:</b>		QC-YB-240145					
<b>Date:</b>		25.DEC.2024			<b>Next Inspection Date:</b>		24.JUNE.2025					
<b>Type Of Inspection:</b>		VISUAL , THOROUGH EXAMINATION & MAGNETIC PARTICLE INSPECTION			<b>Specification:</b>		ASTM E709 & ASTM E 1444 (2016) ASME V Article 7 (2019)					
   		<b>UNIT DESCRIPTION:</b>			DIESEL GENERATOR							
		<b>UNIT S/N:</b>			NGS19072022034							
		<b>PAD EYE S/N:</b>			PE01,PE02							
		<b>INSPECTION RESULT :</b>										
<b>VISUAL , THOROUGH EXAMINATION</b>			VISUAL & MAGNETIC PARTICLE INSPECTION ( M.P.I. ) HAD BEEN DONEON THE AVAILABLE AREAS FOR THE ABOVE DESCRIPTION									
<b>MAGNETIC PARTICLE INSPECTION</b>			Avalibel Critical areas inspected and found free from cracks and other defects									
<b>FINAL RESULTS</b>			unit found satisfactory and free of defects at the time of inspection									
<b>COMMENT:</b>												
Magnetic Particle Inspection With A/C Hand Yoke , Black & White Contrast												
EQUIPMENT DETAILS					PERSON DETAILS			REVIEW BY				
<b>Equipment:</b>	ASTM Test Block	<b>Equipment:</b>	Digital Lux Meter WHITE LIGHT INTENSITY: 3400 Lux	<b>Equipment:</b>	AC/DC Yoke PERMANET HAND MAGNATIC	<b>INSPECTOR NAME:</b>		<b>SENIOR INSPECTOR:</b>	MAHMOUD ALI			
<b>S.No:</b>	1657	<b>S.No:</b>	S.NO:2722003	<b>S.No:</b>	201504048 PY-09	<b>RAO SOHAIL</b>						
<b>Cal Due Date:</b>	24.FEB.2025	<b>Cal Due Date:</b>	24.FEB.2025	<b>Cal Due Date:</b>	24.FEB.2025	<b>QUALIFICATION:</b>		<b>SUPERVISOR:</b>	M.TARIQ			
<b>Whie Contrast Paint Manufacture:</b>	Magnaflux	<b>Batch No:</b>	220602	<b>EXPIRE DATE:</b>	JUN,2025	ASNT LEVEL II MT & PT & VT						
<b>TECHNICAL DETAILS</b>					<b>STAMP &amp; SIGNATURE:</b>							
<b>Black Magnetic Ink Concentration 7 HF</b>			1.2 to 2.4 ml/100 ml							<b>Batch No:220605</b>		
					<b>EXPIRE DATE:</b>					<b>CLIENT:</b>		
					1,JULY,2025							
Original - Client Files		Copy - Area Office		QC/FN/MPI/065		Rev.00		DATED 07 NOV 2021				