

Certificate of Calibration

Al Takamul Yard, North Rumailah South Iraq

• Phone : +964 7810009138 • www.qualitycontrol-iraq.com • E-mail: op@qualitycontrol-iraq.com

Date of Issue: June 15, 2025

Page 1 of 1

REQUEST NUMBER	: By Contract	CUSTOMER DETAILS	
JOB NUMBER	: QC-CAL-25234	Name	Halliburton Worldwide IRAQ (HPS)
CERTIFICATE NUMBER	: QC-CAL-25234-05	Address	Western Burjesia, Oil Street, District Zubair-South Iraq

EQUIPMENT IDENTIFICATION AND SPECIFICATIONS

Description : **Pressure Safety Valve**
 Manufacturer : N/A
 Model : N/A
 Serial Number : PSV15062503
 Location : N2 Tank # 11192491
 Set/Pressure : 200 Psi
 Tolerance : ± 3%
 As Found : In Tolerance
 Calibration Date : June 15, 2025
Calibration Due : June 14, 2026
 Last Calibration : NA



ENVIRONMENTAL CONDITIONS DURING TEST

Ambient Temperature : 28.0 ± 2°C Humidity : 39.0 ± 5 % RH Atm. Pressure : 1011.0 ± 10 hPa

CALIBRATION METHOD

Standard Method API 527 was used to test the unit under test. Test pressure was applied on inlet of unit under test and test was repeated 3 times. Identical repeatings were carried out as recommended in used standard.

REFERENCE EQUIPMENT USED

DESCRIPTION	SERIAL NO.	MAKE / MODEL	CALIBRATION DATE	CALIBRATION DUE DATE
Digital Pressure Gauge	1505119397	Sino Instruments / HS108	05 Nov, 2024	04 Nov, 2025

CALIBRATION TEST RESULTS

Set Pressure on Unit Under Calibration (M)	Ref. Standard Values (A)	Deviation (D=M-A)	Tolerance Limit
Psi	Psi	Psi	± Psi
200.0	198	2	6.0

Calibration results were found to conform as per specified accuracy requirements. Above Instrument has **PASSED** its Calibration.

DEVIATION FROM STANDARD METHOD : None

REMARK (S) :

- The results are as found (no adjustment done).
 The results are post adjustment.

CALIBRATED BY	REVIEWED & APPROVED BY / LAB INCHARGE	CLIENT
 Abdulrahman Loay	 LAB INCHARGE Asjad Rafiq	

