

Test Certificate-Fire Extinguisher

QC Job Number	: QC-CAL-25286	EXAMINATION DATE	25 July 2025
QC Report Number	: QC-CAL-25286-03	EXP.DATE	24 July 2026
Customer Name: Department :	Halliburton Worldwide Iraq. TSS	Location :	Basra, South Iraq
Testing And Inspection Method:	Based On NFPA (National Fire Protection Association); NFPA 10: Standard For Portable Fire Extinguisher.		

THIS IS TO CERTIFY THAT 'WE AT Quality Control (ALTAKAMUL) Have Inspected; Serviced& Refilled Below Stated Items:

Sr.	Extinguisher Type	Serial Number	DESCRIPTION	Weight	Refilling	Maintenance & inspected	Remarks.
01	Powder	213255	FIRE EXTINGUISHER	10 Kg	√	√	Pass
02	Powder	213043	FIRE EXTINGUISHER	10 Kg	√	√	Pass
03	Powder	214340	FIRE EXTINGUISHER	10 Kg	√	√	Pass
04	Powder	218387	FIRE EXTINGUISHER	10 Kg	√	√	Pass

THE ABOVE FIRE EXTINGUISHERS ARE FREE FROM PATENT DEFECTS AND SUITABLE FOR FURTHER USE (IN THE TIME OF INSPECTION)

ENVIRONMENTAL CONDITIONS DURING TESTING:

HUMIDITY 14 % RH	TEMPERATURES MEAN: 29.9°C
------------------	---------------------------

Tested By: Asjad Rafiq

MASTER LOG CERTIFICATE (NEBOSH)

Signature:



00136995/38678

