

Explosion Proof Electric Lights Certificate


AlTakamul Yard, North Rumaila, South Iraq

● Phone : +964 781 0009138 ● www.Qualitycontrol-iraq.com ● E-mail: op@Qualitycontrol-iraq.com

Date of Issue: July 5, 2025

Page 1 of 1

REQUEST NUMBER	: By Mail	APPROVED BY	CALIB IN CHARGE QC
JOB NUMBER	: QC-CAL-25250		
CERTIFICATE NUMBER	: QC-CAL-25250-13		



CUSTOMER DETAILS

Name : **Halliburton Worldwide IRAQ**
 Address : Western Burjesia, Oil Street, District Zubair-South Iraq
 Department : TSS

EQUIPMENT IDENTIFICATION AND SPECIFICATIONS

Description : **Ex Rated Electric Light**
 Rated Frequency : 50 Hz
 Serial Number : EL7525-01
 Inspected By : Abdulrahman Loay
 Inspection Date : July 5, 2025
Due Due : July 4, 2026



ENVIRONMENTAL CONDITIONS DURING TEST

Ambient Temperature	:	29	°C	± 2	°C
Relative Humidity	:	20	%RH	± 5	%RH

INSPECTION METHOD

The above equipment has been inspected in accordance to IEC 60079-17, API RP 505

Serial No.	Parameters Checked	Results
1	Ex Rated by Manufacturer	Satisfactory
2	Torque of enclosure bolts	Satisfactory
3	Maximum Surface Temperature (Under working condition)	Satisfactory
4	Air Tightness of Enclosure	Satisfactory
5	Grounding	Satisfactory
6	Cable Insulations	Satisfactory
7	Electrical Insulation Clean and Dry	Satisfactory
8	All electrical connections Tight	Satisfactory
9	Cables are free of any damage	Satisfactory
10	Has not done any modification	Satisfactory
11	Sealing Gaskets	Satisfactory

Remarks: Its certify that the item(s) described above were examined by prescribed manner. The inspection parameters mentioned above were found satisfactory at the time of inspection. This inspection report does not relieve the contractor/user from his obligation to keep the equipment maintained and use safely.

This certificate may not be reproduced other than in full, unless permission for the publication of an approved extract has been obtained in writing from the director of QC. It does not of itself impute to the subject of the calibration any attributes beyond those shown by the data contained herein.